



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 27-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.28.07.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	27-Jul-20	0:00:00	27-Jul-20	24:00:00	24:00:00	36.00	0.843	
4	27-Jul-20	0:00:00	27-Jul-20	24:00:00	24:00:00	37.00	0.893	
5	27-Jul-20	0:00:00	27-Jul-20	24:00:00	24:00:00	35.00	0.831	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	Today(i.e. 28.07.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	
3	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	
4	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	
5	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	
6	27-Jul-20	0:00:00	27-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.567	0.000	2.567
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	57.274	95.582	152.856
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.86 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11267 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 15757 Cusec 39 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
15356	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
630	0	14295	15757	0	181



for Archita Kaveriga
28/7/2020
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are gross on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:
Unit No.2: 18:30 hrs on 27.07.2020 to 07:05 Hrs on 28.07.2020.