

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 3-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 2-Jul-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 3-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Jul-20	0:00:00	2-Jul-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.03.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-Jul-20	0:00:00	2-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	2-Jul-20	0:00:00	2-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	2-Jul-20	0:00:00	2-Jul-20	24:00:00	24:00:00	40.00	0.954	
5	2-Jul-20	0:00:00	2-Jul-20	24:00:00	24:00:00	39.00	0.891	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Jul-20	0:00:00	2-Jul-20	7:30:00	17:30:00	167	2.880	Today(i.e. 03.07.2020), 1 SSP-RBPH M/cs are running at 10:00 hrs.
		14:00:00		24:00:00				
2	2-Jul-20	0:00:00	2-Jul-20	7:15:00	17:30:00	167	2.862	
		13:45:00		24:00:00				
3	2-Jul-20	0:00:00	2-Jul-20	8:30:00	13:30:00	165	2.204	
		19:00:00		24:00:00				
4	2-Jul-20	0:00:00	2-Jul-20	24:00:00	24:00:00	166	3.978	
5	2-Jul-20	0:00:00	2-Jul-20	6:45:00	11:45:00	164	1.886	
		19:00:00		24:00:00				
6	2-Jul-20	0:00:00	2-Jul-20	7:00:00	11:45:00	166	1.944	
		19:15:00		24:00:00				

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	1.845	15.754	17.599
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	3.859	39.342	43.201
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	96:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11240 Cusec 27 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 34738 Cusec 85 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
10047	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	10929	10481	24257	199

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL