



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 29-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.30.07.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	29-Jul-20	0:00:00	29-Jul-20	24:00:00	24:00:00	35.00	0.821	
4	29-Jul-20	0:00:00	29-Jul-20	24:00:00	24:00:00	37.00	0.867	
5	29-Jul-20	8:00:00	29-Jul-20	22:00:00	14:00:00	34.00	0.466	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	Today(i.e. 30.07.2020), 0 SSP-RBPH M/cs is running at 10:00 hrs.
2	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	
3	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	
4	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	
5	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	
6	29-Jul-20	0:00:00	29-Jul-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.154	0.000	2.154
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	61.579	95.582	157.161
PREVIOUS DAY ACTUAL RUNNING HOURS	62:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12285 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13272 Cusec 32 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
11310	615

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
621	0	11687	13272	0	181



for Aschita Kourange
30-7-2020
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 18:25 hrs on 29.07.2020 to 06:30 Hrs on 30.07.2020.

Unit No.2: 18:35 hrs on 29.07.2020 to 06:35 Hrs on 30.07.20