

DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 4-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 3-Jul-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 4-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Jul-20	0:00:00	3-Jul-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.04.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Jul-20	0:00:00	3-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	3-Jul-20	0:00:00	3-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	3-Jul-20	0:00:00	3-Jul-20	24:00:00	24:00:00	41.00	0.958	
5	3-Jul-20	0:00:00	3-Jul-20	24:00:00	24:00:00	37.00	0.873	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Jul-20	0:00:18:45	3-Jul-20	8:00:24:00	13:15:00	169	2.170	Today(i.e. 04.07.2020), 0 SSP-RBPB M/cs are running at 10:00 hrs.
2	3-Jul-20	0:00:19:00	3-Jul-20	7:15:24:00	12:15:00	169	2.030	
3	3-Jul-20	0:00:19:15	3-Jul-20	3:00:24:00	7:45:00	169	1.280	
4	3-Jul-20	0:00:21:30	3-Jul-20	16:45:24:00	19:15:00	169	3.216	
5	3-Jul-20	0:00:19:30	3-Jul-20	7:00:24:00	11:30:00	167	1.888	
6	3-Jul-20	0:00:19:45	3-Jul-20	3:15:24:00	7:30:00	169	1.248	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	1.831	11.832	13.663
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	5.690	51.174	56.864
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	71:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.48 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 11550 Cusec 28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24684 Cusec 60 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
10928	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	0	10848	10546	14138	196

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPB Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL