

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-20	0:00:00	4-Jul-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.05.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Jul-20	0:00:00	4-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	4-Jul-20	0:00:00	4-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	4-Jul-20	0:00:00	4-Jul-20	24:00:00	24:00:00	40.00	0.939	
5	4-Jul-20	0:00:00	4-Jul-20	24:00:00	24:00:00	37.00	0.869	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-20	0:00:00	4-Jul-20	2:30:00	2:30:00	169	0.428	Today(i.e. 05.07.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	4-Jul-20	0:00:00	4-Jul-20	2:15:00	2:15:00	169	0.382	
3	4-Jul-20	0:00:00	4-Jul-20	2:00:00	2:00:00	170	0.338	
4	4-Jul-20	0:00:00	4-Jul-20	8:45:00	8:45:00	177	1.528	
5	4-Jul-20	0:00:00	4-Jul-20	2:45:00	2:45:00	167	0.464	
6	4-Jul-20	18:00:00	4-Jul-20	22:15:00	4:15:00	181	0.774	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.808	3.914	5.722
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	7.498	55.088	62.586
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	22:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Jul-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres. 121.57 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 25414 Cusec 62 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18554 Cusec 45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
9377	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9377	10403	8151	196

Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.3: 21:20 hrs on 04.07.2020 to 0:45 Hrs on 05.07.2020.

Unit No.5: 21:40 hrs on 04.07.2020 to 7:25 Hrs on 05.07.2020.