

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Jul-20	0:00:00	6-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work.
2	6-Jul-20	0:00:00	6-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	6-Jul-20	0:00:00	6-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	6-Jul-20	0:00:00	6-Jul-20	24:00:00	24:00:00	38.00	0.908	Today (i.e.07.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
5	6-Jul-20	1:00:00	6-Jul-20	22:15:00	21:15:00	38.00	0.778	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Jul-20	0:00:00	6-Jul-20	5:30:00	5:30:00	181	0.974	Today(i.e. 07.07.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	6-Jul-20	0:15:19:15	6-Jul-20	5:45:24:00	10:15:00	187	1.842	
3	6-Jul-20	0:30:00	6-Jul-20	7:15:00	6:45:00	182	1.222	
4	6-Jul-20	0:00:18:45	6-Jul-20	8:00:24:00	13:15:00	185	2.392	
5	6-Jul-20	0:45:19:00	6-Jul-20	7:30:24:00	11:45:00	186	2.134	
6	6-Jul-20	1:00:00	6-Jul-20	7:45:00	6:45:00	181	1.210	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		1.686	9.774	11.460
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		10.508	70.632	81.140
PREVIOUS DAY ACTUAL RUNNING HOURS		45:15:00	54:15:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	24:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	30:15:00	

SSP hydrological data : at 08:00 Hrs on 7-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.68 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16268 Cusec 40 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17552 Cusec 43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7972	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	7516	8247	9305	197



Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL.