



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 8-Jul-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 7-Jul-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs)

Date: 8-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MU	REMARKS
1	7-Jul-20	0:00:00	7-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work.
2	7-Jul-20	0:00:00	7-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	7-Jul-20	0:00:00	7-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	7-Jul-20	0:00:00	7-Jul-20	24:00:00	24:00:00	39.00	0.917	Today (i.e. 08.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
5	7-Jul-20	18:00:00	7-Jul-20	24:00:00	6:00:00	38.00	0.216	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MU	REMARKS
1	7-Jul-20	13:00 18:45	7-Jul-20	16:00 21:15	5:30:00	190	1.030	Today (i.e. 08.07.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	7-Jul-20	0:00:00	7-Jul-20	2:15:00	2:15:00	186	0.420	
3	7-Jul-20	0:00:00	7-Jul-20	0:00:00	0:00:00	0	0.000	
4	7-Jul-20	0:00:00	7-Jul-20	8:45:00	8:45:00	187	1.638	
5	7-Jul-20	0:00:00	7-Jul-20	8:00:00	8:00:00	187	1.506	
6	7-Jul-20	0:00:00	7-Jul-20	0:00:00	0:00:00	0	0.000	

GROSS GENERATION IN (MU)	CHPH (5 X 50MW)	1.133	RBPH (6X200 MW)	4.594	SSP(CHPH+RBPH)	5.727
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		11.641		75.226		86.867
PREVIOUS DAY ACTUAL RUNNING HOURS		30:00:00		24:30:00		
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00		24:30:00		
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00		30:15:00		

SSP hydrological data : at 08:00 Hrs on 8-Jul-20

DATA RECEIVED FROM FLOOD CELL.

RESERVOIR LEVEL IN Metres	121.77 Mtrs.	
AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	22515 Cusec	55 MCM
AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	15653 Cusec	38 MCM

GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
7516	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	7516	6704	8949	198



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No. 8: 17:55 hrs on 07:07.2020 to 8:00 Hrs on 08.07.2020.

Unit No. 9: 18:05 hrs on 07:07.2020 to 8:10 Hrs on 08.07.2020