



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Jul-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 08-Jul-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jul-20	0:00:00	8-Jul-20	0:00:00	0:00:00	0.00	0.000	Unit No. 1 is under L/C for runner blade inspection work. Today (i.e.09.07.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	8-Jul-20	0:00:00	8-Jul-20	0:00:00	0:00:00	0.00	0.000	
3	8-Jul-20	0:00:00	8-Jul-20	0:00:00	0:00:00	0.00	0.000	
4	8-Jul-20	0:00:00	8-Jul-20	24:00:00	24:00:00	38.00	0.903	
5	8-Jul-20	0:00:00 9:00	8-Jul-20	1:00 24:00	16:00:00	38.00	0.588	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Jul-20	0:00 12:45 18:30	8-Jul-20	2:45 16:00 21:45	9:15:00	191	1.730	Today(i.e. 09.07.2020), 0 SSP-RBPB M/cs are running at 10:00 hrs.
2	8-Jul-20	0:15:00	8-Jul-20	3:00:00	2:45:00	186	0.516	
3	8-Jul-20	0:15:00	8-Jul-20	7:30:00	7:15:00	187	1.348	
4	8-Jul-20	0:00:00	8-Jul-20	8:00:00	8:00:00	187	1.506	
5	8-Jul-20	0:00:00	8-Jul-20	0:00:00	0:00:00	0	0.000	
6	8-Jul-20	0:30:00	8-Jul-20	3:30:00	3:00:00	186	0.564	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	1.491	5.664	7.155
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	13.132	80.890	94.022
PREVIOUS DAY ACTUAL RUNNING HOURS	40:00:00	30:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	20:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	19:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Jul-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13053 Cusec 32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16558 Cusec 41 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
9956	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	0	9956	10007	6551	198



for Archita Kanungo  
9.7.2020  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPB Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.5: 17:10 hrs on 08:07.2020 to 6:20 Hrs on 09.07.2020.

Unit No.6: 17:00 hrs on 07:07.2020 to 6:25 Hrs on 09.07.2020