



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0.00	0.000	Today(i.e. 31.07.18), 1 CHPH M/c is running at 08:00 hrs.
2	30-Jul-18	0:00:00	30-Jul-18	24:00:00	24:00:00	18.00	0.410	
3	30-Jul-18	00:00:00 17:05	30-Jul-18	6:15 24:00	13:10:00	18.00	0.230	
4	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0.00	0.000	
5	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	Today(i.e. 31.07.18), no SSP-RBPH M/c is scheduled.
2	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	
3	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	
4	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	
5	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	
6	30-Jul-18	0:00:00	30-Jul-18	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)

RBPH (6X200 MW)

SSP(CHPH+RBPH)

GROSS GENERATION IN(MUs)	0.640	0.000	0.640
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	6.144	0.000	6.144
PREVIOUS DAY ACTUAL RUNNING HOURS	37:10:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMOROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Jul-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 111.55 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4026 Cusec 10 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5661 Cusec 14 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5552	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
628	0	5552	5661	0	0



Signature
AEE (EMC)
NCA, INDORE
31/7/18

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai.
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV Asoj, Dhule-1 and Raj-1 lines are in service right now.

2. 400 kV kasor is under L/C.

3. RBPH-SCO Running Detail:-

Unit no.6 :2:15 hrs on 31.07.18 to 09:55hrs on 31.07.2018.

Unit no.2: 22:10 hrs on 30.07.18 to 7:40 hrs on 31.07.18.