



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0.00	0.000	
3	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0.00	0.000	
4	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0.00	0.000	
5	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	
3	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	
4	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	
5	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	
6	4-Jul-18	0:00:00	4-Jul-18	0:00:00	0:00:00	0	0.000	

CHPH (5 X 50MW)

RBPH (6X200 MW)

SSP(CHPH+RBPH)

GROSS GENERATION IN(MUs)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Jul-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 108.78 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7142 Cusec 17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 1877 Cusec 5 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1242	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
614	0	1259	0	0	1877



Handwritten Signature
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for maintaining environmental flow into the downstream.

NA- Not Available as communication failure at SSP.