



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jul-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 11.07.2019), 1 CHPH M/c is running at 10:00 hrs.
2	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	10-Jul-19	12:30:00	10-Jul-19	24:00:00	11:30:00	36.00	0.397	
4	10-Jul-19	0:00:00	10-Jul-19	24:00:00	24:00:00	37.00	0.858	
5	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 11.07.2019), no SSP-RBPH M/c is scheduled.
2	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	
3	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	
4	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	
5	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	
6	10-Jul-19	0:00:00	10-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.255	0.000	1.255
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.675	0.000	9.675
PREVIOUS DAY ACTUAL RUNNING HOURS	35:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.09 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6145 Cusec 15 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7444 Cusec 18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6270	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
649	0	6233	7444	0	192



[Signature]
11/7/19
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CEWRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , and Dhule-1 lines are in service.

2. SCO Mode Running Detail: Nil