



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Jul-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 17-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jul-19	0:00:00	17-Jul-19	24:00:00	24:00:00	36.00	0.858	Today(i.e. 18.07.2019), 2 CHPH M/cs are running at 10:00 hrs.
2	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	17-Jul-19	0:00:00	17-Jul-19	24:00:00	24:00:00	36.00	0.834	
4	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0.00	0.000	
5	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 18.07.2019), no SSP-RBPH M/c is scheduled.
2	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	
3	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	
4	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	
5	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	
6	17-Jul-19	0:00:00	17-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.692	0.000	1.692
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.464	0.000	19.464
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.79 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2931 Cusec 7.17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10137 Cusec 24.80 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8769	648

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
644	0	8780	10137	0	189



[Signature]
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNI,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail: Nil