



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Jul-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 02.07.2019), 1 CHPH M/c is running at 10:00 hrs.
2	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0.00	0.000	
4	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0.00	0.000	
5	1-Jul-19	4:30:00	1-Jul-19	24:00:00	19:30:00	34.00	0.641	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 02.07.2019), no SSP-RBPH M/c is scheduled.
2	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	
3	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	
4	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	
5	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	
6	1-Jul-19	0:00:00	1-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.641	0.000	0.641
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.641	0.000	0.641
PREVIOUS DAY ACTUAL RUNNING HOURS	19:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.86 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4414 Cusec 11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3666 Cusec 9 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2863	510

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
557	0	2863	3666	0	181



(Signature)
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 21:30 hrs on 01.07.2019 to 06:45 hrs on 02.07.2019