



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Jul-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 19-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Jul-19	0:00:00	19-Jul-19	24:00:00	24:00:00	36.00	0.842	Today(i.e. 20.07.2019), 2 CHPH M/cs are running at 10:00 hrs.
2	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	19-Jul-19	0:00:00	19-Jul-19	24:00:00	24:00:00	36.00	0.838	
4	19-Jul-19	17:30:00	19-Jul-19	24:00:00	6:30:00	37.00	0.233	
5	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.07.2019), no SSP-RBPH M/c is scheduled.
2	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	
3	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	
4	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	
5	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	
6	19-Jul-19	0:00:00	19-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.913	0.000	1.913
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	23.081	0.000	23.081
PREVIOUS DAY ACTUAL RUNNING HOURS	54:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.18 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 39553 Cusec 96.77 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11971 Cusec 29.29 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8781	651

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
634	0	11039	11971	0	191



for Shree
20-7-19
20, 1919

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 03:00hrs on 20.07.2019 to 6:10 hrs on 20.07.2019