



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Jul-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 23-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Jul-19	0:00:00	23-Jul-19	24:00:00	24:00:00	36.00	0.848	Today(i.e. 24.07.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	23-Jul-19	17:00:00	23-Jul-19	24:00:00	7:00:00	37.00	0.246	
3	23-Jul-19	0:00:00	23-Jul-19	11:30:00	11:30:00	37.00	0.406	
4	23-Jul-19	0:00:00	23-Jul-19	24:00:00	24:00:00	37.00	0.871	
5	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 24.07.2019), no SSP-RBPH M/c is scheduled.
2	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	
3	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	
4	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	
5	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	
6	23-Jul-19	0:00:00	23-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.371	0.000	2.371
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	32.387	0.000	32.387
PREVIOUS DAY ACTUAL RUNNING HOURS	66:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.96 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 31536 Cusec 77 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13578 Cusec 33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12845	640

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
638	0	12827	13578	0	199



AEE (EMC)  
NCA, INDORE

*Signature*  
24/7/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNI, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil