



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Jul-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 24-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Jul-19	00:00:00 19:00	24-Jul-19	17:40:00 24:00:00	22:40:00	37.00	0.801	Today(i.e. 25.07.2019), 3 CHPH M/cs are running at 10:00 hrs.
2	24-Jul-19	0:00:00	24-Jul-19	13:30:00	13:30:00	37.00	0.476	
3	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0.00	0.000	
4	24-Jul-19	0:00:00	24-Jul-19	24:00:00	24:00:00	37.00	0.867	
5	24-Jul-19	17:30:00	24-Jul-19	24:00:00	6:30:00	36.00	0.223	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 25.07.2019), no SSP-RBPH M/c is scheduled.
2	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	
3	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	
4	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	
5	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	
6	24-Jul-19	0:00:00	24-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.367	0.000	2.367
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	34.754	0.000	34.754
PREVIOUS DAY ACTUAL RUNNING HOURS	66:40:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15362 Cusec 38 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13690 Cusec 33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12872	638

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
674	0	12872	13690	0	200



for Archita Kaurange
J.E. (Elect),
NCA
25.7.19

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil