



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Jul-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 25-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Jul-19	00:00 17:00	25-Jul-19	12:00 24:00	19:00:00	37.00	0.688	Today(i.e. 26.07.2019), 2 CHPH M/cs are running at 10:00 hrs.
2	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0.00	0.000	
4	25-Jul-19	0:00:00	25-Jul-19	24:00:00	24:00:00	37.00	0.881	
5	25-Jul-19	0:00:00	25-Jul-19	24:00:00	24:00:00	37.00	0.867	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 26.07.2019), no SSP-RBPH M/c is scheduled.
2	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	
3	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	
4	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	
5	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	
6	25-Jul-19	0:00:00	25-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.436	0.000	2.436
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	37.190	0.000	37.190
PREVIOUS DAY ACTUAL RUNNING HOURS	67:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Jul-19

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 121.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6957 Cusec 17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14144 Cusec 35 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12840	673

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
692	0	12847	14144	0	199



for
25/07/19

AEE (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.3:19:00 hrs on 25.07.2019 to 07:15 hrs on 26.07.2019.