



નર્મદા નિયંત્રણ અધિકારી
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Jul-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 27-Jul-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|--------------|-----------|---------------|-------------|----------------|-------------------|---|
| | | | | | | | | |
| 1 | 27-Jul-19 | 0:00 9:30 | 27-Jul-19 | 3:00 22:30 | 16:00:00 | 37.00 | 0.587 | Today(i.e. 28.07.2019), 2 CHPH M/cs are running at 10:00 hrs. |
| 2 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 24:00:00 | 24:00:00 | 39.00 | 0.909 | |
| 5 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 24:00:00 | 24:00:00 | 37.00 | 0.873 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|---|
| | | | | | | | | |
| 1 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 28.07.2019), no SSP-RBPH M/c is scheduled. |
| 2 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 27-Jul-19 | 0:00:00 | 27-Jul-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 2.369 | 0.000 | 2.369 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 41.938 | 0.000 | 41.938 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 64:00:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 72:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 72:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 28-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.75 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6463 Cusec 16 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 12913 Cusec 32 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 12580 | 622 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 700 | 0 | 11613 | 12913 | 0 | 198 |



for
Archita Kavnungo
J.E. CE (Lect 2)
EMC, NCA
28-7-19
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 0:00 hrs on 28.07.2019 to 7:35 hrs on 28.07.2019.