



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Jul-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 03-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jul-19	00:00 17:00	3-Jul-19	07:30 24:00	14:30:00	34.00	0.474	Today (i.e. 04.07.2019), 1 CHPH M/c is running at 10:00 hrs.
2	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0.00	0.000	
3	3-Jul-19	12:30:00	3-Jul-19	24:00:00	11:30:00	35.00	0.379	
4	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0.00	0.000	
5	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	Today (i.e. 04.07.2019), no SSP-RBPH M/c is scheduled.
2	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	
3	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	
4	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	
5	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	
6	3-Jul-19	0:00:00	3-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.853	0.000	0.853
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	2.083	0.000	2.083
PREVIOUS DAY ACTUAL RUNNING HOURS	26:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Jul-19

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 120.03 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16033 Cusec 39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5472 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) In Cusec

HR	GODBOLE
3305	526

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
595	0	4753	5472	0	181



AEE (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.3:23:00 hrs on 03.07.2019 to 09:10 hrs on 04.07.2019

Unit No.6: 03:50 hrs on 04.07.2019 to 06:10 hrs on 04.07.2019

Unit No.4: 01:05 hrs on 04.07.2019 to 07:05 hrs on 04.07.2019