



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Jul-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Jul-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jul-19	12:40:00	5-Jul-19	24:00:00	11:20:00	35.00	0.367	Today(i.e. 06.07.2019), 1 CHPH M/c is running at 10:00 hrs.
2	5-Jul-19	17:00:00	5-Jul-19	24:00:00	7:00:00	33.00	0.228	
3	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0.00	0.000	
4	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0.00	0.000	
5	5-Jul-19	0:00:00	5-Jul-19	12:45:00	12:45:00	34.00	0.415	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 06.07.2019), no SSP-RBPH M/c is scheduled.
2	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	
3	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	
4	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	
5	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	
6	5-Jul-19	0:00:00	5-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.010	0.000	1.010
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	4.091	0.000	4.091
PREVIOUS DAY ACTUAL RUNNING HOURS	31:05:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14620 Cusec 36 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6290 Cusec 15 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5307	576

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
609	0	5350	6290	0	184



नर्मदा नियंत्रण प्राधिकरण

AEE (EMC)
NCA, INDORE

for display
06/07/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.3: 23:20 hrs on 05.07.2019 to 09:25 hrs on 06.07.2019

Unit No.4: 23:25 hrs on 05.07.2019 to 08:25 hrs on 06.07.2019