



નર્મદા નિયંત્રણ અધિકારી  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Jul-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 06-Jul-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Jul-19	0:00:00	6-Jul-19	24:00:00	24:00:00	35.00	0.804	Today(i.e. 07.07.2019), 1 CHPH M/c is running at 10:00 hrs.
2	6-Jul-19	17:00:00	6-Jul-19	24:00:00	7:00:00	33.00	0.231	
3	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0.00	0.000	
4	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0.00	0.000	
5	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	Today(i.e. 07.07.2019), no SSP-RBPH M/c is scheduled.
2	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	
3	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	
4	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	
5	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	
6	6-Jul-19	0:00:00	6-Jul-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.035	0.000	1.035
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	5.126	0.000	5.126
PREVIOUS DAY ACTUAL RUNNING HOURS	31:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Jul-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.62 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 31113 Cusec 76 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6479 Cusec 16 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5350	609

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
613	0	5386	6479	0	186



for Archita Kanungo  
7.7.19.  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , and Dhule-1 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 20:50 hrs on 06.07.2019 to till now.

Unit No.2: 00:25 hrs on 06.07.2019 to till now.