

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0.00	0.000	Unit No. 4 is under L/C (AoH) Today(i.e. 10.06.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	9-Jun-20	0:00:00	9-Jun-20	24:00:00	24:00:00	44.00	1.044	
4	9-Jun-20	17:00:00	9-Jun-20	24:00:00	7:00:00	44.00	0.306	
5	9-Jun-20	12:00:00	9-Jun-20	17:10:00	5:10:00	43.00	0.258	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020
2	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	
3	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	Unit No. 1,2,3,4,5 are not available for generation due to civil work at Garudeshwar Weir.
4	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	
5	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	
6	9-Jun-20	0:00:00	9-Jun-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUS)	1.608	0.000	1.608
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	13.615	0.000	13.615
PREVIOUS DAY ACTUAL RUNNING HOURS	36:10:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Jun-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres. 126.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 54735 Cusec 134 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7934 Cusec 19 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8270	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	7178	7934	0	514



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**Unit No.3: 18:50 hrs on 09.06.2020 to 5:45 Hrs on 10.06.2020.**

**Unit No.4: 19:00 hrs on 09.06.2020 to 5:50 Hrs on 10.06.2020**