

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.14.06.2020) 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	13-Jun-20	10:00:00	13-Jun-20	24:00:00	14:00:00	48.00	0.655	
4	13-Jun-20	0:00:00	13-Jun-20	9:43:00	9:43:00	49.00	0.463	
5	13-Jun-20	17:00:00	13-Jun-20	23:30:00	6:00:00	48.00	0.284	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0	0.000	Today(i.e. 14.06.2020), 2 SSP-RBPH M/cs are running at 10:00 hrs.
2	13-Jun-20	0:00:00	13-Jun-20	24:00:00	24:00:00	205	4.734	
3	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0	0.000	
4	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0	0.000	
5	13-Jun-20	0:00:00	13-Jun-20	24:00:00	24:00:00	204	4.792	
6	13-Jun-20	0:00:00	13-Jun-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.402	9.526	10.928
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	19.620	9.526	29.146
PREVIOUS DAY ACTUAL RUNNING HOURS	29:43:00	48:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	72:00:00	

SSP hydrological data : at 08:00 Hrs on 14-Jun-20

**DATA RECEIVED FROM FLOOD CELL.**

- RESERVOIR LEVEL IN Metres 127.59 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19230 Cusec 47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6605 Cusec 16 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
7179	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	6203	6605	0	551



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**Unit No.3: 02:15 hrs on 14.06.2020 to 7:40 Hrs on 14.06.2020.**

**Unit No.4: 02:25 hrs on 14.06.2020 to 7:45 Hrs on 14.06.2020.**