

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.15.06.2020) 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	14-Jun-20	0:00:00	14-Jun-20	24:00:00	24:00:00	48.00	1.153	
4	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0.00	0.000	
5	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0	0.000	Today(i.e. 15.06.2020), 3 SSP-RBPH M/cs are running at 10:00 hrs.
2	14-Jun-20	0:00:00	14-Jun-20	24:00:00	24:00:00	204	4.846	
3	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0	0.000	
4	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0	0.000	
5	14-Jun-20	0:00:00	14-Jun-20	24:00:00	24:00:00	203	4.884	
6	14-Jun-20	0:00:00	14-Jun-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		1.153	9.730	10.883
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		20.773	19.256	40.029
PREVIOUS DAY ACTUAL RUNNING HOURS		24:00:00	48:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	48:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	72:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 32859 Cusec 80 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21996 Cusec 54 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6203	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	4984	5374	16622	552



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, & Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.3: 17:50 hrs on 14.06.2020 to 7:40 Hrs on 15.06.2020.

Unit No.4: 17:55 hrs on 14.06.2020 to 7:45 Hrs on 15.06.2020.