

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	16-Jun-20	0:00:00	16-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.17.06.2020) 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	16-Jun-20	0:00:00	16-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	16-Jun-20	0:00:00	16-Jun-20	19:00:00	19:00:00	49.00	0.911	
4	16-Jun-20	11:00:00	16-Jun-20	24:00:00	13:00:00	49.00	0.631	
5	16-Jun-20	0:00:00	16-Jun-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	16-Jun-20	0:00:00	16-Jun-20	0:00:00	0:00:00	0	0.000	Today(i.e. 17.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	16-Jun-20	0:00:00	16-Jun-20	24:00:00	24:00:00	200	4.704	
3	16-Jun-20	0:00:00	16-Jun-20	24:00:00	24:00:00	199	4.706	
4	16-Jun-20	0:00:00	16-Jun-20	0:00:00	0:00:00	0	0.000	
5	16-Jun-20	0:00:00	16-Jun-20	24:00:00	24:00:00	199	4.716	
6	16-Jun-20	0:00:00	16-Jun-20	24:00:00	24:00:00	200	4.718	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.542	18.844	20.386
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	23.468	52.588	76.056
PREVIOUS DAY ACTUAL RUNNING HOURS	32:00:00	96:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 17-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 127.46 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18114 Cusec 44 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 40061 Cusec 98 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
5307	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	7890	7170	32891	551

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NA