

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Jun-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 17-Jun-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

Date: 18-Jun-20

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Jun-20	0:00:00	17-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.18.06.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	17-Jun-20	0:00:00	17-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	17-Jun-20	10:30:00	17-Jun-20	24:00:00	13:30:00	49.00	0.649	
4	17-Jun-20	0:00:00	17-Jun-20	16:30:00	16:30:00	49.00	0.799	
5	17-Jun-20	16:25:00	17-Jun-20	24:00:00	7:35:00	49.00	0.355	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	194	4.420	Today(i.e. 18.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	194	4.422	
3	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	194	4.436	
4	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	192	4.468	
5	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	191	4.374	
6	17-Jun-20	0:00:00	17-Jun-20	24:00:00	24:00:00	194	4.462	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.803	26.582	28.385
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	25.271	79.170	104.441
PREVIOUS DAY ACTUAL RUNNING HOURS	37:35:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Jun-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 127.16 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 24092 Cusec 59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 51670 Cusec 126 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8659	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9934	10210	41460	544



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details: