

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Jun-20	0:00:00	18-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.19.06.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	18-Jun-20	0:00:00	18-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	48.00	1.149	
4	18-Jun-20	0:00:00	18-Jun-20	0:00:00	0:00:00	0.00	0.000	
5	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	49.00	1.117	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	183	4.340	Today(i.e. 19.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	180	4.286	
3	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	182	4.308	
4	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	181	4.352	
5	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	176	4.246	
6	18-Jun-20	0:00:00	18-Jun-20	24:00:00	24:00:00	182	4.328	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.266	25.860	28.126
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		27.537	105.030	132.567
PREVIOUS DAY ACTUAL RUNNING HOURS		48:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Jun-20

**DATA RECEIVED FROM FLOOD CELL.**

- RESERVOIR LEVEL IN Metres. 126.77 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16189 Cusec 40 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 52212 Cusec 128 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
10907	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	11441	10787	41425	536

Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 & Raj-2 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**NIL**