

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Jun-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 21-Jun-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 22-Jun-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jun-20	0:00:00	21-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.22.06.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	21-Jun-20	0:00:00	21-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	48.00	1.111	
4	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	48.00	1.132	
5	21-Jun-20	15:00:00	21-Jun-20	23:00:00	8:00:00	47.00	0.363	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	182	4.200	Today(i.e. 22.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	180	4.168	
3	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	179	4.176	
4	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	180	4.194	
5	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	173	4.122	
6	21-Jun-20	0:00:00	21-Jun-20	24:00:00	24:00:00	172	4.216	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.606	25.076	27.682
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	34.981	181.654	216.635
PREVIOUS DAY ACTUAL RUNNING HOURS	56:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 125.59 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 19096 Cusec 47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 52696 Cusec 129 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
12925	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	13374	12790	39906	509

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL