

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jun-20	0:00:00	24-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.25.06.2020) 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	24-Jun-20	0:00:00	24-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	24-Jun-20	0:00:00	24-Jun-20	23:30:00	23:30:00	45.00	1.021	
4	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	45.00	1.064	
5	24-Jun-20	0:00:00 9:00	24-Jun-20	0:30 24:00	16:00:00	44.00	0.666	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	175	4.140	Today(i.e. 25.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	175	4.172	
3	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	175	4.158	
4	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	175	4.198	
5	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	168	4.062	
6	24-Jun-20	0:00:00	24-Jun-20	24:00:00	24:00:00	177	4.210	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.751	24.940	27.691
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		43.040	256.742	299.782
PREVIOUS DAY ACTUAL RUNNING HOURS		63:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 25-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 124.53 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30387 Cusec 74 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 55077 Cusec 135 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
14928	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	15310	13970	41107	487

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL