



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Jun-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 27-Jun-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 28-Jun-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-20	0:00:00	27-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.28.06.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	27-Jun-20	0:00:00	27-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	27-Jun-20	0:00:00 8:00	27-Jun-20	1:00:00 24:00	17:00:00	43.00	0.714	
4	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	44.00	1.014	
5	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	42.00	0.990	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	172	4.084	Today(i.e. 28.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	170	4.034	
3	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	170	4.030	
4	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	172	4.098	
5	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	166	3.982	
6	27-Jun-20	0:00:00	27-Jun-20	24:00:00	24:00:00	172	4.112	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.718	24.340	27.058
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		51.045	330.464	381.509
PREVIOUS DAY ACTUAL RUNNING HOURS		65:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 28-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 123.42 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 31258 Cusec 76 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 54489 Cusec 133 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
14828	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14383	14089	40400	465



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL