

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-20	0:00:00	28-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.29.06.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	28-Jun-20	0:00:00	28-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	43.00	0.992	
4	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	42.00	0.995	
5	28-Jun-20	8:30:00	28-Jun-20	24:00:00	15:30:00	41.00	0.626	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	174	4.084	Today(i.e. 29.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	172	4.038	
3	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	170	4.064	
4	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	170	4.074	
5	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	166	3.978	
6	28-Jun-20	0:00:00	28-Jun-20	24:00:00	24:00:00	173	4.112	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.613	24.350	26.963
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	53.658	354.814	408.472
PREVIOUS DAY ACTUAL RUNNING HOURS	63:30:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Jun-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 123.08 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29872 Cusec 73 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 54592 Cusec 134 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
14383	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14678	13979	40613	458



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL