

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 3-Jun-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 2-Jun-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0.00	0.000	Unit No. 4 is under L/C (AoH) Today(i.e. 03.06.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	2-Jun-20	0:00:00	2-Jun-20	23:00:00	23:00:00	38.00	0.871	
4	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0.00	0.000	
5	2-Jun-20	8:00:00	2-Jun-20	24:00:00	16:00:00	40.00	0.617	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020 Unit No. 1,2,3,4,5 are not available for generation due to civil work at Garudeshwar Weir. Today(i.e. 03.06.2020), 0 SSP-RBPH
2	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	
3	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	
4	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	
5	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	
6	2-Jun-20	0:00:00	2-Jun-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP (CHPH+RBPH)
GROSS GENERATION IN (MUs)		1.488	0.000	1.488
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		2.375	0.000	2.375
PREVIOUS DAY ACTUAL RUNNING HOURS		39:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Jun-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres. 123.02 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 51012 Cusec 125 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8356 Cusec 20 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
5356	412

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
566	0	5985	8356	0	448

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE (E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.4: 18:25 hrs on 02.06.2020 to 07:05 hrs on 03.06.2020

Unit No.5: 18:15 hrs on 02.06.2020 to 07:10 hrs on 03.06.2020