

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jun-20	0:00:00	29-Jun-20	0:00:00	0:00:00	0.00	0.000	Today (i.e.30.06.2020) 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	29-Jun-20	0:00:00	29-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	29-Jun-20	9:00:00	29-Jun-20	24:00:00	15:00:00	41.00	0.608	
4	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	42.00	0.983	
5	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	41.00	0.963	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	172	4.048	Today(i.e. 30.06.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	170	4.010	
3	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	170	4.012	
4	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	170	4.052	
5	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	164	3.966	
6	29-Jun-20	0:00:00	29-Jun-20	24:00:00	24:00:00	172	4.068	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.554	24.156	26.710
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	56.212	378.970	435.182
PREVIOUS DAY ACTUAL RUNNING HOURS	63:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Jun-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 122.73 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30726 Cusec 75 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 56193 Cusec 137 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec



HR	GODBOLE
14678	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	15352	15863	40330	451

Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

NIL