

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0.00	0.000	Unit No. 4 is under L/C (AoH) Today(i.e. 08.06.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0.00	0.000	
3	7-Jun-20	6:30:00	7-Jun-20	24:00:00	17:30:00	42.00	0.729	
4	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0.00	0.000	
5	7-Jun-20	0:00:00	7-Jun-20	24:00:00	24:00:00	42.00	1.008	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	Unit No. 6 under AoH from 9:30 Hrs dated 18.05.2020
2	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	
3	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	Unit No. 1,2,3,4,5 are not available for generation due to civil work at Garudeshwar Weir.
4	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	
5	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	
6	7-Jun-20	0:00:00	7-Jun-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	1.737	0.000	1.737
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	9.982	0.000	9.982
PREVIOUS DAY ACTUAL RUNNING HOURS	41:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

**SSP hydrological data : at 08:00 Hrs on 8-Jun-20**

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres. 125.30 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 38166 Cusec 93 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10272 Cusec 25 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec



HR	GODBOLE
9010	579

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	10034	10272	0	495

Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

**NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.**

**1. 400 kV SSP Asoj, Kasor, Raj-2 & Dhule-1 lines are in service.**

**2. SCO Mode Running Detail:**

**RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:**

**Unit No.3: 18:10 hrs on 07.06.2020 to 6:25 Hrs on 08.06.2020.**

**Unit No.4: 18:15 hrs on 07.06.2020 to 6:30 Hrs on 08.06.2020.**