



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jun-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jun-21	0:00:00	10-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 11.06.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	10-Jun-21	0:00:00	10-Jun-21	0:00:00	0:00:00	0.00	0.000	
3	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	38.00	0.873	
4	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	37.00	0.886	
5	10-Jun-21	18:00:00	10-Jun-21	23:00:00	5:00:00	36.00	0.177	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	167	3.954	Today (i.e. 11.06.2021), 5 SSP-RBPH M/c is running at 10:00 hrs.
2	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	164	3.876	
3	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	164	3.864	
4	10-Jun-21	15:40:00	10-Jun-21	24:00:00	8:20:00	161	1.334	
5	10-Jun-21	0:00:00	10-Jun-21	24:00:00	24:00:00	159	3.800	
6	10-Jun-21	0:00:00	10-Jun-21	15:45:00	15:45:00	170	2.642	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.936	19.470	21.406
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	20.896	160.206	181.102
PREVIOUS DAY ACTUAL RUNNING HOURS	53:00:00	120:05:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	120:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	120:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.62 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8473 Cusec 20.73 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 38411 Cusec 93.98 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
12498	617

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
619	0	38411	11748	26663	392



Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

*Rajesh Sharma*  
11/6/21