



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Jun-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 15-Jun-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Jun-21	0:00:00	15-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 16.06.2021), 2 SSP-CHPH M/cs are running at 09:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	15-Jun-21	0:00:00	15-Jun-21	24:00:00	24:00:00	32.00	0.745 ✓	
3	15-Jun-21	0:00:00	15-Jun-21	0:00:00	0:00:00	0.00	0.000	
4	15-Jun-21	0:00:00	15-Jun-21	24:00:00	24:00:00	32.00	0.751 ✓	
5	15-Jun-21	0:00 16:00	15-Jun-21	2:30 24:00	10:30:00	31.00	0.318 ✓	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Jun-21	0:00:00	15-Jun-21	24:00:00	24:00:00	160	3.792 ✓	Today (i.e. 16.06.2021), 2 SSP-RBPH M/cs are running at 09:00 hrs.
2	15-Jun-21	0:00 21:15	15-Jun-21	3:15 24:00	6:00:00	156	0.930 ✓	
3	15-Jun-21	0:00:00	15-Jun-21	24:00:00	24:00:00	158	3.720 ✓	
4	15-Jun-21	0:00:00	15-Jun-21	24:00:00	24:00:00	160	3.794 ✓	
5	15-Jun-21	0:00 21:30	15-Jun-21	3:30 24:00	6:00:00	150	0.908 ✓	
6	15-Jun-21	0:15:00	15-Jun-21	24:00:00	23:45:00	162	3.784 ✓	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.814 ✓	16.928 ✓	18.742 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	29.577 ✓	253.256 ✓	282.833 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	58:30:00 ✓	107:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	49:00:00 ✓	106:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00 ✓	104:45:00	

SSP hydrological data : at 08:00 Hrs on 16-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 116.82 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14334 Cusec ✓ 35.07 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 45504 Cusec ✓ 111.33 MCM ✓

GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
12499	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
616	0	12536	12109	33395	357



*Rajesh Sharma*  
18/6/21  
Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service. ✓

2. SCO Mode Detail:-

Nil