



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Jun-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 25-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jun-21	0:00:00	25-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 26.06.2021), 2 SSP-CHPH M/c are running at 09:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	25-Jun-21	0:00:00	25-Jun-21	24:00:00	24:00:00	25.00	0.586	
3	25-Jun-21	0:00:00	25-Jun-21	0:00:00	0:00:00	0.00	0.000	
4	25-Jun-21	0:00:00	25-Jun-21	0:00:00	0:00:00	0.00	0.000	
5	25-Jun-21	11:00:00	25-Jun-21	24:00:00	13:00:00	26.00	0.322	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Jun-21	0:00:00	25-Jun-21	24:00:00	24:00:00	158	3.722	Today (i.e. 26.06.2021), 4 SSP-RBPH M/cs are running at 09:00 hrs.
2	25-Jun-21	00:00 17:45	25-Jun-21	14:15 24:00	20:30:00	154	3.114	
3	25-Jun-21	00:00 17:15	25-Jun-21	9:00 24:00	15:45:00	154	2.390	
4	25-Jun-21	0:00:00	25-Jun-21	24:00:00	24:00:00	155	3.668	
5	25-Jun-21	00:00 17:30	25-Jun-21	8:45 24:00	15:15:00	151	2.284	
6	25-Jun-21	0:00:00	25-Jun-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.908	15.178	16.086
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	41.260	392.640	433.900
PREVIOUS DAY ACTUAL RUNNING HOURS	37:00:00	99:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	103:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	100:45:00	

SSP hydrological data : at 08:00 Hrs on 26-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 115.11 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15457 Cusec 37.82 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 34973 Cusec 85.56 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
7984	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
612	0	8042	8316	26657	334	30.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 6: 03:55 hrs on 26.06.2021 to 06:30 hrs on 26.06.2021.

Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

(Handwritten Signature)
J-E (EMC)
EMC, N.C.A.
26.06.2021