



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 28-Jun-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 27-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-21	0:00:00	27-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 28.06.2021), 2 SSP-CHPH M/c are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	27-Jun-21	0:00:00	27-Jun-21	24:00:00	24:00:00	24.00	0.561 ✓	
3	27-Jun-21	0:00:00	27-Jun-21	0:00:00	0:00:00	0.00	0.000	
4	27-Jun-21	0:00:00	27-Jun-21	0:00:00	0:00:00	0.00	0.000	
5	27-Jun-21	00:00 9:30	27-Jun-21	4:00 24:00	18:30:00	25.00	0.438 ✓	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	27-Jun-21	0:00:00	27-Jun-21	24:00:00	24:00:00	155	3.634 ✓	Today (i.e. 28.06.2021), 3 SSP-RBPH M/cs are running at 10:00 hrs.
2	27-Jun-21	00:00 12:45	27-Jun-21	8:15 24:00	19:30:00	154	2.932 ✓	
3	27-Jun-21	00:00 14:15	27-Jun-21	8:30 24:00	18:15:00	153	2.730 ✓	
4	27-Jun-21	00:00 13:30	27-Jun-21	10:15 24:00	20:45:00	155	3.164 ✓	
5	27-Jun-21	00:00 13:45	27-Jun-21	8:00 24:00	18:15:00	149	2.664 ✓	
6	27-Jun-21	0:00:00	27-Jun-21	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.999 ✓	15.124 ✓	16.123 ✓
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	43.407	423.342	466.749 ✓
PREVIOUS DAY ACTUAL RUNNING HOURS	42:30:00	100:45:00 ✓	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	104:00:00 ✓	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	103:45:00 ✓	

SSP hydrological data : at 08:00 Hrs on 28-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.68 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29424 Cusec 71.99 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 36103 Cusec 88.33 MCM ✓
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9135 ✓	617 ✓

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614 ✓	0 ✓	9643 ✓	8445 ✓	27658 ✓	327 ✓	30.50 ✓



Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA. ✓

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 6: 19:05 hrs on 27.06.2021 to 05:40 hrs on 28.06.2021.