



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Jun-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 28-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-21	0:00:00	28-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 29.06.2021), 2 SSP-CHPH M/c are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	28-Jun-21	0:00:00	28-Jun-21	24:00:00	24:00:00	24.00	0.560 ✓	
3	28-Jun-21	0:00:00	28-Jun-21	0:00:00	0:00:00	0.00	0.000	
4	28-Jun-21	0:00:00	28-Jun-21	0:00:00	0:00:00	0.00	0.000	
5	28-Jun-21	0:00:00	28-Jun-21	24:00:00	24:00:00	22.00	0.563 ✓	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	28-Jun-21	0:00:00	28-Jun-21	24:00:00	24:00:00	154	3.612 ✓	Today (i.e. 29.06.2021), 3 SSP-RBPH M/cs are running at 10:00 hrs.
2	28-Jun-21	0:00:00	28-Jun-21	14:10:00	14:10:00	152	2.094 ✓	
3	28-Jun-21	0:00:18:15	28-Jun-21	8:30:24:00	14:15:00	152	2.112 ✓	
4	28-Jun-21	0:00:00	28-Jun-21	24:00:00	24:00:00	154	3.618 ✓	
5	28-Jun-21	0:00:14:10	28-Jun-21	8:00:24:00	17:50:00	145	2.584 ✓	
6	28-Jun-21	14:15:00	28-Jun-21	24:00:00	9:45:00	153	1.460 ✓	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.123	15.480	16.603
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	44.530	438.822	483.352
PREVIOUS DAY ACTUAL RUNNING HOURS	48:00:00	104:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	103:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	100:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 114.44 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 23993 Cusec 58.70 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 37679 Cusec 92.18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9643	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
600	0	9574	8896	28783	325	31.00



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil