



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

**DAILY PLANT REPORT(DPR) OF Sardar Sarovar Project Power Houses**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Jun-21  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 02-Jun-21

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Jun-21	0:00:00	2-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 03.06.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs.  SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	2-Jun-21	0:00:00	2-Jun-21	24:00:00	24:00:00	42.00	1.000	
3	2-Jun-21	0:00:00	2-Jun-21	24:00:00	24:00:00	43.00	1.003	
4	2-Jun-21	9:00:00	2-Jun-21	21:00:00	12:00:00	42.00	0.501	
5	2-Jun-21	0:00:00	2-Jun-21	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	2-Jun-21	0:00:00	2-Jun-21	7:45:00	7:45:00	184	1.410	Unit No. 1 is not available due to Governing System Problem from 20:45hrs on 2.06.21.  Today (i.e. 03.06.2021), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	2-Jun-21	0:00 14:40 20:45	2-Jun-21	8:00 18:50 24:00	15:25:00	186	2.814	
3	2-Jun-21	0:00 20:15	2-Jun-21	8:15 24:00	12:00:00	185	2.182	
4	2-Jun-21	0:00 18:50	2-Jun-21	8:30 24:00	13:40:00	185	2.504	
5	2-Jun-21	0:00 20:30	2-Jun-21	8:45 24:00	12:15:00	183	2.208	
6	2-Jun-21	0:00 14:15	2-Jun-21	1:00 24:00	10:45:00	187	1.968	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.504	13.086	15.590
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	5.033	27.408	32.441
PREVIOUS DAY ACTUAL RUNNING HOURS	60:00:00	71:50:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	79:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	58:30:00	

SSP hydrological data : at 08:00 Hrs on 3-Jun-21

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres: 122.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs): 13405 Cusec
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs): 34431 Cusec
- GOG WATER REQUIREMENT (Next Day) in Cusec: 32.80 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec: 84.24 MCM

HR	GODBOLE
15522	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14997	13463	20968	450

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule - 2 & Raj-2 lines are in service.  
2. SCO Mode Detail:-

Nil



*For Archita Kawange  
J.E. (Electg)  
3.06.2021*

Rajesh Sharma  
Executive Engineer (EMC)  
NCA, INDORE