



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Jun-21
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Jun-21

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Jun-21	0:00:00	7-Jun-21	0:00:00	0:00:00	0.00	0.000	Today (i.e. 08.06.2021), 2 SSP-CHPH M/cs are running at 10:00 hrs. SSP CHPH Unit No. 1 is under C.O.H. from 15.03.2021.
2	7-Jun-21	0:00:00	7-Jun-21	0:00:00	0:00:00	0.00	0.000	
3	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	40.00	0.944	
4	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	41.00	0.953	
5	7-Jun-21	4:30:00	7-Jun-21	16:00:00	11:30:00	39.00	0.437	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	182	4.240	Today (i.e. 08.06.2021), 5 SSP-RBPH M/c is running at 10:00 hrs.
2	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	183	4.188	
3	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	183	4.232	
4	7-Jun-21	0:00:00	7-Jun-21	0:00:00	0:00:00	0	0.000	
5	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	181	4.158	
6	7-Jun-21	0:00:00	7-Jun-21	24:00:00	24:00:00	184	4.256	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.334	21.074	23.408
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	14.847	100.932	115.779
PREVIOUS DAY ACTUAL RUNNING HOURS	59:30:00	120:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	120:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	120:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Jun-21

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.16 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6924 Cusec 16.94 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 47229 Cusec 115.55 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14007	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
600	0	13107	12620	34609	422



Rajesh Sharma
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Dhule-1, Dhule - 2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil