



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0.00	0.000	
3	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0.00	0.000	
4	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0.00	0.000	
5	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	
3	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	
4	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	
5	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	
6	12-Jun-18	0:00:00	12-Jun-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Jun-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 106.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 949 Cusec 2 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2615 Cusec 6 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1999	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
623	0	1989	0	0	2615



जल वसंत - जल धरम

for
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadoadra