



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Jun-18  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 15-Jun-18

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0.00	0.000	
3	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0.00	0.000	
4	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0.00	0.000	
5	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	
3	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	
4	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	
5	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	
6	15-Jun-18	0:00:00	15-Jun-18	0:00:00	0:00:00	0	0.000	

**CHPH (5 X 50MW)**

**RBPH (6X200 MW)**

**SSP(CHPH+RBPH)**

GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Jun-18

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 106.23 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4686 Cusec 11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2894 Cusec 7 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2245	606

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
603	0	2291	0	0	2894



for Archita Kanungo  
16.6.18

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

AEE (EMC)  
NCA, INDORE