



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Jun-18
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Jun-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0.00	0.000	
3	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0.00	0.000	
4	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0.00	0.000	
5	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	
3	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	
4	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	
5	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	
6	1-Jun-18	0:00:00	1-Jun-18	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)		RBPH (6X200 MW)		SSP(CHPH+RBPH)	
GROSS GENERATION IN(MUs)					0.000		0.000		0.000	
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					0.000		0.000		0.000	
PREVIOUS DAY ACTUAL RUNNING HOURS					0:00:00		0:00:00			
TODAY'S DC (Schedule) Planned (in Hours)					0:00:00		0:00:00			
DAY AHEAD (TOMMORROW) DC (in Hours)					0:00:00.		0:00:00			

SSP hydrological data : at 08:00 Hrs on 2-Jun-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 106.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9041 Cusec 22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2255 Cusec 6 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1645	643

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
611	0	1644	0	0	2255



जल संधार - जल संयोज

for Shunbe 2/6/18
SE, E/M, NCA.

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

AEE (EMC)
NCA, INDORE

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
II) SSP-RBPH SCQ Mode Operation:- No M/c was in SCQ Mode due to low Dam level.
III) IBPT operated for maintaining environmental flow into the downstream.