



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Jun-18  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 05-Jun-18

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).
2	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0.00	0.000	
3	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0.00	0.000	
4	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0.00	0.000	
5	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m)
2	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	
3	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	
4	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	
5	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	
6	5-Jun-18	0:00:00	5-Jun-18	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)					0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)					0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS					0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (24 Hours)					0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Jun-18  
DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 106.42 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1736 Cusec 4 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2247 Cusec 5 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
1628	649

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
619	0	1628	0	0	2247



जल शक्ति - जल सेवा

AEE (BMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.  
III) IBPT operated for maintaining environmental flow into the downstream.