



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jun-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Jun-19

(CHPH 5X50 MW)

| Unit No. | START     |          | STOP      |          | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS   |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|---|
| 1        | 10-Jun-19 | 0:00:00  | 10-Jun-19 | 20:00:00 | 20:00:00    | 35.00          | 0.662             | Today(i.e. 11.06.2019), 1 CHPH M/c is running at 10:00 hrs. |
| 2        | 10-Jun-19 | 0:00:00  | 10-Jun-19 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |
| 3        | 10-Jun-19 | 17:00:00 | 10-Jun-19 | 24:00:00 | 7:00:00     | 35.00          | 0.229             |   |
| 4        | 10-Jun-19 | 0:00:00  | 10-Jun-19 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |
| 5        | 10-Jun-19 | 0:00:00  | 10-Jun-19 | 0:00:00  | 0:00:00     | 0.00           | 0.000             |   |

(RBPH 6X200 MW)

| Unit No. | START     |         | STOP      |         | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS   |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|---|
| 1        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             | Today(i.e. 11.06.2019), no SSP-RBPH M/c is scheduled.<br><br>Unit No.5 is under outage from 10.06.2019 at 9:00 Hrs..<br>Unit No.4 is under outage from 03.06.2019 at 9:00 Hrs.. |
| 2        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 3        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 4        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 5        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 6        | 10-Jun-19 | 0:00:00 | 10-Jun-19 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 0.891           | 0.000           | 0.891          |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 7.956           | 0.000           | 7.956          |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 27:00:00        | 0:00:00         |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00        | 0:00:00         |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 24:00:00        | 0:00:00         |                |

SSP hydrological data : at 08:00 Hrs on 11-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.02 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 706 Cusec 2 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5507 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR   | GODROLE |
|------|---------|
| 4527 | 328     |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODROLE | OVER FLOW | HR   | CHPH | RBPH | Ev. Less |
|---------|-----------|------|------|------|----------|
| 641     | 0         | 4499 | 5507 | 0    | 395      |



for Shrivastava  
11-6-19  
JOINCA  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CEWRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, and Raj-2 lines are in service.

2.SCO Mode Detail:-Unit No.1: 05:00hrs on 11.06.2019 to 07:10 hrs on 11.06.2019