



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Jun-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 15-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 16.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	15-Jun-19	9:00:00	15-Jun-19	24:00:00	15:00:00	34.00	0.493	
3	15-Jun-19	20:30:00	15-Jun-19	24:00:00	3:30:00	33.00	0.113	
4	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	15-Jun-19	0:00:00	15-Jun-19	3:00:00	3:00:00	34.00	0.101	

(RBP/1 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 16.06.2019), no SSP-RBP/1 M/c is scheduled. Unit No.5 is under outage from 10.06.2019 at 9:00 Hrs., Unit No.4 is under outage from 03.06.2019 at 9:00 Hrs.,
2	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	
3	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	
4	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	
5	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	
6	15-Jun-19	0:00:00	15-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBP/1 (6X200 MW)	SSP(CHPH+RBP/1)
GROSS GENERATION IN(MUs)	0.707	0.000	0.707
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.860	0.000	11.860
PREVIOUS DAY ACTUAL RUNNING HOURS	21:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 16 Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.94 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5615 Cusec 13.74 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5794 Cusec 14.18 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODROLE
3652	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODROLE	OVER FLOW	HR	CHPH	RBP/1	Ev. Loss
889	0	6	5794	0	392

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP, Member (Power), NVDA, Bhopal
- GoMah, CEWRD, Mumbai
- GoG, CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasar and Dhule-2 lines are in service.

2. SC Mode Running Detail:

Unit No.2: 02:25 hrs on 16.06.2019 to 10:35 hrs on 16.06.2019.

Unit No.2: 02:35 hrs on 16.06.2019 to 10:40 hrs on 16.06.2019.

For Ashrita Kanungo
J. E. (Elect.)
EMC, NCA
16.6.19

AEE (EMC)
NCA, INDORE