



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18 Jun 19
ISSUE TIME: 10:00 Hrs
FOR DATE: 17 Jun 19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jun-19	0:00:00	17-Jun-19	18:30:00	18:30:00	35.00	0.606	Today(i.e. 18.06.2019), 1 CHPH M/cs are running at 10:00 hrs.
2	17-Jun-19	0:00:00	17-Jun-19	2:00:00	2:00:00	32.00	0.064	
3	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0.00	0.000	
5	17-Jun-19	10:00:00	17-Jun-19	24:00:00	14:00:00	34.00	0.462	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 18.06.2019), no SSP-RBPB M/c is scheduled. Unit No.5 is under outage from 10.06.2019 at 9:00 Hrs.
2	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	
3	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	
4	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	
5	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	
6	17-Jun-19	0:00:00	17-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUS)	1.132	0.000	1.132
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	14.071	0.000	14.071
PREVIOUS DAY ACTUAL RUNNING HOURS	34:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.73 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1271 Cusec 3.11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6709 Cusec 16.41 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4858	1236

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
1324	0	4522	6709	0	390

for Taisey Ak 18/6/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasar and Dhule-2 lines are in service.

2. SCD Mode Running Detail:

Unit No.4: 01:25 hrs on 18.06.2019 to 05:30 hrs on 18.06.2019.

Unit No.1: 04:05 hrs on 18.06.2019 to 06:05 hrs on 18.06.2019.

AEE (EMC)
NCA, INDORE