



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Jun-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 19-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUHs	REMARKS
1	19-Jun-19	17:00:00	19-Jun-19	22:00:00	5:00:00	34.00	0.166	Today(i.e. 20.06.2019), 1 CHPH M/c is running at 10.00 hrs.
2	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0.00	0.000	
4	19-Jun-19	0:00:00	19-Jun-19	24:00:00	24:00:00	36.00	0.807	
5	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUHs	REMARKS
1	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 20.06.2019), no SSP(RBPH) M/c is scheduled.  Unit No.5 is under outage from 10.06.2019 at 9:00 Hrs. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs.
2	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	
3	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	
4	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	
5	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	
6	19-Jun-19	0:00:00	19-Jun-19	0:00:00	0:00:00	0	0.000	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUHs)					0.973	0.000	0.973
CUMMULATIVE GROSS GEN. FOR MONTH (MUHs)					16.015	0.000	16.015
PREVIOUS DAY ACTUAL RUNNING HOURS					29:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20 Jun-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.63 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3073 Cusec 7.52 MUM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6144 Cusec 15.01 MUM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4309	1552

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	TR	CHPH	RBPH	Ev. Loss
1124	0	4344	6144	0	389

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(ERM),SSNLI,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 KV SSP Asoj, Kasor and Dhule-2, Dhule-1 lines are in service.  
2. SCO Mode Running Detail:Nil.

*[Signature]*  
20/6/19  
AFF (EMC)  
NCA, INDORE