



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 22-Jun-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 21-Jun-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 22.06.2019), 1 CHPH M/c is running at 10:00 hrs.
2	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0.00	0.000	
3	21-Jun-19	14:00:00	21-Jun-19	17:00:00	3:00:00	36.00	0.998	
4	21-Jun-19	0:00:00	21-Jun-19	24:00:00	24:00:00	35.00	0.810	
5	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0.00	0.000	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	Today(i.e. 22.06.2019), no SSP-RBPB M/c is scheduled. Unit No.6 is under outage from 17.06.2019 at 9:00 Hrs..
2	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	
3	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	
4	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	
5	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	
6	21-Jun-19	0:00:00	21-Jun-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	0.908	0.000	0.908
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	17.730	0.000	17.730
PREVIOUS DAY ACTUAL RUNNING HOURS	27:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 22-Jun-19

DATA RECEIVED FROM FLOOD CELL

RESERVOIR LEVEL IN Metres	119.60 Mtrs.	
AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs).	9570 Cusec	23.41 MCM
AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs).	5695 Cusec	13.93 MCM
GOG WATER REQUIREMENT (Next Day) in Cusec		

HR	GODBOLE
3978	1102

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
1075	0	3929	5695	0	388

Cop: To:

HEA Executive Member/Member (Power)/Member (Civil)/SE(LMC)/DD (Hydromet), NCA,INDORE.

GoP Member(Power),NVEDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor and Dhule-2 lines are in service.

2. SCO Mode Running Detail:NIL

for Archita Kharanga  
J. E. (Elect.)  
EMC, NCA.  
22.6.19

AE (EMC)  
NCA, INDORE